

813-222  
577.581  
A-98  
A-1000 600P  
E-1 1/29/81

**CODES & STANDARDS**

The electrical installation shall comply with the following codes and standards:

1. Underwriter's Laboratories, Inc. - U.L.
2. National Electric Code or the NFPA - NEC
3. New York City, N.Y. Electric Code
4. Occupational Safety & Health Act - OSHA

**SHOP DRAWINGS AND CATALOG CUTS**

The Contractor shall prepare and submit to the Engineer for approval, detailed shop drawings, catalog cuts and wiring diagrams in accordance with the requirements of the clause entitled "Working Drawings and Catalog Cuts and Brochures."

Shop drawings will be required for the following:

- 1.
- 2.
- 3.

Wiring Diagrams will be required for the following:

- 1.
- 2.
- 3.

Catalog Cuts will be required for the following:

- 1.
- 2.
- 3.

**SUBSTITUTIONS**

Any substitution to electrical items described on this contract, will only be permitted upon written approval by The Engineer.

**QUALITY ASSURANCE**

The Contractor shall have had experience on at least two projects involving the installation and completion of at least equal to those required under this contract in the applicable Section thereof.

All work performed under this contract shall be skilled workmen of the trade involved.

**INSPECTION**

All stages of the installation will be inspected for compliance with the requirements of the Contract Drawings and Specifications. Replace a portion of the construction that does not meet such requirements, to the satisfaction of the Engineer.

Provide proper facilities as the Engineer may require for access and observation at the construction site.

**CUTTING AND PATCHING**

1. All cutting and patching required for equipment included in these Specifications shall be done by this Contractor. If cutting is done due to failure to perform preliminary roughing work this Contractor will be responsible for the cost of the additional patching.
2. In those portions of the building where new floors, or walls, or partitions are required to be constructed, the Contractor shall furnish and locate all required sleeves and inserts before the floors, or walls, or partitions are constructed. Where sleeves and inserts were not installed, or where sleeves and inserts were incorrectly located the Contractor shall be responsible for the cost of any required cutting and patching.
3. All drilling above and adjoining occupied tenant spaces or common spaces shall be performed at times approved by the Engineer.
4. This Contractor shall not do any cutting that may impair the structural building construction. No holes, except for small sleeves, may be drilled in beams or other structural members, without obtaining prior approval. All work shall be done in a neat manner by mechanics skilled in their trades and as approved.

**DISSIMILAR METALS**

1. Dissimilar metals as used herein shall be those which are incompatible in the presence of moisture, as determined from their position in the electrochemical series or from test data. When dissimilar metals come in contact, paint the joint both inside and out with approved paint so as to exclude moisture from the joint, or provide a suitable barrier separating the metals.
2. Transition from one metal to a dissimilar metal shall only be made at boxes or other enclosures, except where otherwise specified herein or shown on the Contract Drawings.

**RACEWAYS AND BOXES**

1. Where sizes of raceway or boxes are not indicated, the Contractor shall size these items as required for the installation.
2. Flexible metal conduit shall be used for final connection of lighting fixtures and wiring devices to be installed in hung ceilings or in removable hollow metal partition construction. When designated by the Engineer on final approved tenant drawings, flexible metal conduit shall be used for final connection of lighting fixtures and wiring devices to be installed in movable walls or movable partitions. Flexible metal conduit shall be used in such designated movable walls and movable partitions at no additional cost to the Authority.

3. All conduit and tubing shall be cut square and reamed at the ends. Red lead shall be applied to all exposed threads after joints have been made up clean and tight.

4. Conduit and tubing runs shall be mechanically and electrically continuous from service starting to all outlets. Conduit shall enter and be securely connected to cabinet, junction box, pull box or outlet box by means of locknuts on the outside and inside and a insulated bushing on the inside. In tubing or flexible metal conduit, the one compression locknut shall be made wrench-tight. All locknuts shall be the bonding type with sharp edges for digging into the metal wall of an enclosure and shall be installed in a manner that will assure a locking and electrically continuous installation. Locknuts and bushings will not be required where conduits are screwed into tapped connections.

5. All vertical runs of conduit or tubing terminating in the bottoms of wall boxes or cabinets, or similar locations, shall be protected from the entrance of foreign material prior to the installation of conductors.

6. Unless otherwise specified, all conduit and tubing shall be installed concealed. In general, all conduit and tubing shall be run in hung ceilings and furred spaces where they exist. Where conduit is run exposed it shall be securely supported with zinc coated malleable iron pipe straps or other approved metals.

7. Every conduit system shall be installed complete before any conductors are drawn in. Wire pulling lubricants, when utilized, shall be in accordance with the requirements of Underwriters' Laboratories, Inc., applicable to the specific conductor or cable insulation and raceway material.

8. Where required, and approved by Engineer extra deep or extra shallow outlet boxes shall be used to facilitate the installation of the conduit system.

**OUTLET DEVICES**

1. All device plates for wall outlets (Power & Telephone) shall be brushed satin finish anodized aluminum. Device plates for telephone outlets shall contain a bushed hole.
2. All convenience type receptacles shall be of the grounding type.

**GROUNDING**

1. Metal raceways, metal enclosures of electrical devices and equipment, lighting standards and other equipment shall be completely grounded in a approved manner.
2. Proper hardware required for complete grounding system, shall be installed by the Contractor.

**FASTENERS**

Provide inserts, expansion shield lugs, anchors, bolts with nuts and washers, or any other type of fastening devices required to fasten panels or other equipment to foundations, floors, walls or ceiling. Unless otherwise specified herein or shown on the Contract Drawings, all fasteners shall be hot-dipped galvanized and of sizes and types recommended by the equipment manufacturer and as approved by the Engineer.

**WIRES**

1. Unless otherwise specified or specifically indicated on the drawing, all conductors for lighting and power shall be tinned single conductor annealed copper with type THHN or THW insulation, 600 volt and a minimum of 98 percent conductivity.

Where existing circuits, in the header duct, are extended into the P/T cells use THW cable - Where cables are shown on contract drawings to be installed from panels to electrical equipment via header duct, P/T cell or GDT, use THHN cable.

2. In lieu of a separate green grounding wire and grounding bushings, flexible metallic raceway for connection of lighting fixtures may be utilized as the grounding conductor if a locking type construction shakeproof connector especially designed to insure positive grounding is provided.

**Color Coding**

The Contractor shall match the color-coding that is being used in the Building - any deviation due to limited quantities of cable, may be permitted upon written approval by the Engineer

System Voltage		
120/208V	Phase	277/480V
Black	A	Brown
Red	B	Orange
Blue	C	Yellow
White	Neutral	Gray
Green	Ground	Green

**Connections**

The wiring for lighting, receptacles including outlets for miscellaneous devices and for electric power, including all 120/208V connections into the cellular floor systems shown on the drawings, shall be furnished and installed complete from point of service connection to all outlets indicated on drawings.

**CABLE SPLICING**

1. No splices or joints will be permitted in either feeders or branches except at outlets or accessible terminal, splice or junction boxes.

2. All materials required for making splices and or terminations shall be supplied in complete kits, no older than 6 months (the Contractor shall also be responsible to insure that all materials furnished will not adversely affect the physical or electrical properties of any other, or of the wire or cable itself). Kits shall be manufactured by Mac Prod. Inc., - Kearny, N.J. or approved equal.

3. Where the Contractor makes connections to existing wires, he shall open and disconnect the existing splices from such wires and install new splices to include the existing as indicated.

4. All splices for wire sizes #10 and smaller shall be made with insulated spring connector applied to twisted conductors. Two half lapped layers of vinyl tape extending a distance of not less than one inch from the connector shall be applied. Splices other than the forementioned, will be permitted at discretion of the Engineer.

**Lighting Fixture Hookup Wire**

1. Splices shall not be permitted in any run of fixture hookup wire.
2. Connections to branch circuit conductors and to existing fixture wiring shall be made by insulated spring connectors or crimp type connectors.

**IDENTIFICATION OF WIRES**

1. All wires shall be identified by circuits in all cabinets, boxes, wiring troughs and other enclosures, and at all terminal points, i.e., receptacles, etc.
2. The circuit designations shall be as shown on the Contract Drawings, or as directed by the Engineer. Tags shall be attached to wires so that they will be readily visible.
3. Brady, B-500 vinyl cloth wire and terminal markers shall be used for all wire identification.

**LIGHTING FIXTURES**

**General**

1. This clause of the Specification covers the furnishing of labor, materials, equipment and the installation of all indoor and outdoor lighting fixtures, lighting equipment and the installation of lamps for all electrical outlets in the building, including the connection of fixtures and equipment to the electric wiring system as shown on plans. As specified hereinafter, certain fixtures shall be furnished by this Contractor while others will be furnished by the Authority for storage, installation and connection by this Contractor.

2. The Contractor is directed to review the applicable Architectural and Electrical Drawings for details on fixture construction and installation media for fixtures to be furnished by the Authority. The drawings represent a concept, not a final design, and reasonable changes to design may be made by the Authority.

3. All luminaires and lighting equipment shall be delivered to the premises complete, including all mounting accessories and components necessary for the proper operation of the equipment exclusive of lamps, whether furnished by the Contractor or by the Authority.

4. All fixtures and components shall be made in accordance with the National Electrical Code, all local codes applying and shall conform to all applicable requirements of the Underwriter's Laboratories, Inc.

5. All recessed fixtures furnished by the Authority will be furnished with fixture wiring only. The Contractor shall provide wiring extensions in flexible conduit and necessary fittings to complete the wiring system connections.

**LAMPS**

Lamps shall be those manufactured by General Electric Co., Westinghouse Electric Corp. or Sylvania Electric Products Inc. All fluorescent lamps shall be warm white. Incandescent lamps shall be rated at 125 volts except where otherwise noted.

The Contractor shall install new lamps in all new fixtures, and fixtures that are supplied by the Authority. The Authority will supply fluorescent lamps for building type fixtures only, i.e., 1"x4", 4"x4", 20"x50" and 20"x100". All other lamps shall be furnished by the Contractor.

Prior to the issuance of the certificate of final completion, all lamps which are missing, broken or burnt-out shall be furnished and replaced by the Contractor to the satisfaction of the Engineer.

**Installation And Locating of Fixtures**

Fixture locations as indicated on the electrical drawings are generalized and approximate. The Contractor shall carefully verify fixture locations with Architectural plans, reflected ceiling plans and other reference data prior to installation.

**Wiring**

1. Wiring between fluorescent and starting equipment shall be leads furnished with the have equal or better insulation. All other wiring within fluorescent fixture to the splice with the requirements of the latest Electrical Code.

2. Unless otherwise specified in conjunction with incandescent of the latest issue or be not less than No. 16 gauge tape or tubing at all points. Wiring shall be concealed within the fixture design or mount.

3. Connections of wires to terminals shall be made in a neat electrically and mechanically ing. The number of wires in lampholder or other accessory is designed to

4. Joints in wiring within light fixture wiring to the wiring that they will be mechanically soldered and taped to provide conductors being joined. 1 types of adequately insulated connectors may be furnished application and tools employed manufacturer's recommendation

5. Wiring channels and wireways or sharp edges throughout, must pass and may be substituted with insulated bushings and exit of flexible wiring

**Fluorescent Lamp Ballasts**

1. Ballasts shall provide and particular fluorescent lamp Ballasts shall be of high operation of Rapid Start L

2. The ballast shall be protected starting from the date of defects in workmanship or service program providing incurred in the replacement

**SUPPORTS**

1. Recessed fixtures shall be and accessories. Where ne enclosure housings shall be concrete pour requirements plaster rings, saddle hang or rolled metal shapes with maintain continuous alignment

2. Fixtures shall be attached not depend upon lathing or in suspended ceiling shall bars attached to runners or Mounting splines or other rigidity shall be provided passivated, and shall be Fastening devices shall be require the use of special shall not be used in place

**FINAL CLEANUP AND FIELD TESTS**

After completion of the entire

1. The Contractor, before final all lighting fixtures, glass plates, service fittings, Contract, and shall insure completed or revised schedule of equipment, cables, and

2. The Contractor shall repair as no additional cost to installation, relocation

3. In addition to other test disciplines, perform field demonstrate the reliability the Engineer 48 hours after field tests shall be performed

- a. Operate all electrical unless otherwise directed

- b. Test all wires and cables 1000 volt Megohmmeter together with an out of the Engineer, any practice or applicable equipment involved.

- c. Should the foregoing such defects and re-ins is satisfactory in all

THIS DOCUMENT IS THE PROPERTY OF THE AIRPORTS & WTC AUTHORITY. IT IS TO BE USED FOR THE PROJECT ONLY. IT IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT PERMISSION IN WRITING FROM THE AIRPORTS & WTC AUTHORITY.

REVISIONS					
NO.	DATE	APPD.	DESCRIPTION	NO.	DATE

APPD.	DESCRIPTION	APPD.	DESCRIPTION

*[Signature]*  
ASST. CHIEF ENGINEER  
OF DESIGN & RESEARCH

*[Signature]*  
ENGINEER OF DESIGN  
AIRPORTS & WTC

CHIEF ELECTRICAL ENGINEER

DATE 12-23-80

THE PORT  
THE WORK  
TOWER